

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

TEST REPORT

Name & Address of the customer

Khumpui Academy, Khumulwng,
Radhapur, Water sample from
Khumpui Academy, Khumulwng,
Radhapur, Tripura

Report No : SLWTL/2017/5247
Report Date : 13-10-2025
Sample ID : 9E8N5W46CL
Date of Receipt of Sample : 09/10/2025, 11.30 am
Date(s) of Performance : 13/10/2025
Ref. No. & Date : NIL
ULR No : TC735025000012262F

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results :

1.	Description of Sample (As declared by customer)	: Drinking Water
2.	Volume of Sample Received	: 2 lit
3.	Sample Mark (if any, given by the customer)	: NIL
4.	Date of Sampling by the Customer	: 09/10/2025
5.	Source & Place of Sampling	: Water sample from Khumpui Academy, Khumulwng, Radhapur
6.	Environmental conditions during sampling	: NA
7.	Sampling Plan & Procedures used	: NA

**Report
Prepared by**

Signature :

Name : Samir Acharjee

Designation : Chemist

For State Level Water Testing Laboratory

Signature :

Name : Sujoy Paul

Designation : Technical Manager
Authorized Signatory

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of State Level Water Testing Laboratory, PWD(DWS)
- The reserved part of sample(s) shall be retained for 15 days from the date of Completion of Test.

Contact Person : Er. Rajib Majumder,
Quality Manager, State Level Water Testing Laboratory
Mobile : 9402120089, Email : qmgttripura@gmail.com, Website : www.dws.tripura.gov.in

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

Report No : SLWTL/2017/5247
Sample ID : 9E8N5W46CL

Analysis of Result

SN	Characteristic	Acceptable Limit (as per BIS 10500:2012)	Permissible Limit (as per BIS 10500:2012)	Method of Test	Results
1	Turbidity in N.T.U	1	5	APHA 24th Edition 2130 B	0.84
2	pH value at 25°C	6.5-8.5	No Relaxation	APHA 24th Edition 4500-H+ B	5.75
3	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 24th Edition 3500-Fc B	0.017

BDL - Below Detection Level for Fluoride - <0.2 mg/l, Arsenic - <0.009 mg/l, Iron - <0.1 mg/l, Magnesium - <2 mg/l, Manganese - <0.01 mg/l

Report Prepared by

Signature

Name : **Samir Acharjee**

Designation : **Chemist**

For State Level Water Testing Laboratory

Signature

Name : **Sujoy Paul**

Designation : **Technical Manager**

Authorized Signatory

-: End Of Report :-

Contact Person : Er. Rajib Majumder

Quality Manager, State Level Water Testing Laboratory.

Mobile : 9402120089, Email : qmgtripura@gmail.com, Website : www.dws.tripura.gov.in