

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

Report No : SLWTL/2017/5247
Sample ID : 9E8N5W46CL

Analysis of Result

SN	Characteristic	Acceptable Limit (as per BIS 10500:2012)	Permissible Limit (as per BIS 10500:2012)	Method of Test	Results
1	Turbidity in N.T.U	1	5	APHA 24th Edition 2130 B	0.84
2	pH value at 25°C	6.5-8.5	No Relaxation	APHA 24th Edition 4500-H+ B	5.75
3	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 24th Edition 3500-Fe B	0.017

BDL - Below Detection Level for Fluoride - <0.2 mg/l, Arsenic - <0.009 mg/l, Iron - <0.1 mg/l, Magnesium - <2 mg/l, Manganese - <0.01 mg/l

Report Prepared by

Signature

Name

: Samir Acharjee

Designation

: Chemist

For State Level Water Testing Laboratory

Signature

Name

Sujoy Paul

Designation Technical Manager

Authorized Signatory

:- End Of Report :-

Contact Person : Fr. Rajib Majumder
Quality Manager, State Level Water Testing Laboratory,
Mobile : 9402120089, Email : qmgtripura@gmail.com, Website : www.dws.tripura.gov.in